



PIPE SUPPORT

NOTE:

SAND BACKFILL SHALL CONFORM TO SSPWC 200-1.5 WITH <0.5% WATER, 90-100% PASSING NO.4 SIEVE AND 0-5% PASSING NO.200 SIEVE, UNLESS OTHERWISE SPECIFIED.

REVISION	DATE	BY	DESCRIPTION
4	11/04	P&I	GENERAL
5	03/06	P&I	GENERAL
6	08/07	P&I	ADD SAND BACKFILL

APPROVED: **Susan Mulligan**
Digitally signed by Susan Mulligan
 DN: cn=Susan Mulligan, c=US
 Date: 2007.12.28 09:08:08 -08'00'
 MANAGER OF ENGINEERING DATE

**CALLEGUAS MUNICIPAL
 WATER DISTRICT**

THOUSAND OAKS CALIFORNIA

STANDARD DRAWINGS

BACKFILL FOR CROSSING
 BENEATH EXISTING
 UTILITIES

DWG NO

1103