



**TYPICAL SECTION**  
NTS

**NOTES:**

1. THE DETAIL IS FOR STRUCTURAL PROTECTION OF EXISTING PIPELINE ONLY. REFER TO STATE AND LOCAL REGULATIONS FOR ADDITIONAL SANITARY SEPARATION AND PROTECTION REQUIREMENTS.
2. EQUIVALENT SPONGE PRODUCT FROM FOLLOWING MANUFACTURERS ARE ACCEPTABLE:  
S & S PLASTICS, INC. AMERICAN NATIONAL RUBBER (MODEL 4311N)

<b>REVISION</b>	<b>DATE</b>	<b>BY</b>	<b>DESCRIPTION</b>	<b>CALLEGUAS MUNICIPAL WATER DISTRICT</b>	<u>STANDARD DRAWINGS</u>	<u>DWG NO</u>
2	03/02	P&I	GENERAL		<b>UTILITY CROSSING OVER EXISTING PIPELINE 6" TO 1' COVER</b>	<b>1101</b>
3	11/04	P&I	GENERAL			
4	03/06	P&I	GENERAL			
APPROVED <u>S. Mulligan 3/14/06</u> <small>Digitally signed by S. Mulligan 3/14/06 DN: CN=S. Mulligan 3/14/06, C=US, O= = Calleguas MWD, OU=Engineering Date: 2006.03.14 08:44:29 -08'00'</small> <b>MANAGER OF ENGINEERING</b>				THOUSAND OAKS	CALIFORNIA	